

Texecom Intruder Integration

Continuing TDSi's mission to make integration seamless, integration of Intruder Alarm Panels is now available using true TCP/IP integration between the alarm panel and EXgarde™ to provide a comprehensive view of the alarm system and zone states from within the EXgarde™ Management Software.

Intruder events displayed in EXgarde™

Any event raised on the intruder alarm panel - from system problems through to set/unset and full alarm events - are now displayed within EXgarde™ in the same manner as Access Events.

Alarms may be created from these events to control icons on the site plan, providing a more efficient operational view of the system.

Intruder zone status displayed in EXgarde™

Intruder panels are added to EXgarde™ in the same manner as a Door Controller.

From these panels, you can view the status of all the intruder panel zones to identify which ones are active or in fault condition and action them accordingly.

System status displayed in EXgarde™

Identify the status of the Intruder Panel to see if it is set, part set or unset from within EXgarde™. This can be effective when checking the status of remote sites.

Remote arm / disarm from EXgarde™ events

Configure the system to allow the Intruder Alarm Panel to be set and unset by using your access control readers.

The system can be configured to only be set /unset when authorised intruder operators present their credentials for added security.



Date/Time	Event	Source	Detail 1	Detail 2	Detail 3
22/08/2011 17:43	Confirmed Alarm	Test	1	1	Alarm
22/08/2011 17:45	Zone Reinstate	Panel Test	Zone1	1	Alarm
22/08/2011 17:46	Unknown	Undefined Event	20000	1	1
22/08/2011 17:46	Zone Restore	Panel Test	Zone1	1	Alarm
22/08/2011 17:47	Duress Alarm	Test	1	1	Alarm
22/08/2011 17:49	Exit Started	Test	1	1	Alarm
22/08/2011 17:49	Auto Arm Started	Test	1	1	Alarm
22/08/2011 17:49	Area Armed	Test	1	1	Alarm
22/08/2011 17:49	Duress Alarm	Test	1	1	Alarm
22/08/2011 17:49	Confirmed Alarm	Test	1	1	Alarm
22/08/2011 17:49	Panel Reset	Test	1	1	Alarm
22/08/2011 17:49	Bell Tamper	Test	1	1	Alarm

System Requirements

- Minimum operating system of windows 7 PRO or Server 2009.
- Minimum of EXgarde PRO software installed.
- Additional workstation licence.

Ordering Information

Part No. 4420-2407

Description: Texecom integration module

DS0079 - Issue 3